ELECTRICAL INSTALLATION CONDITION REPORT



A. Details	of the Client	/Person Orde	ring the l	Report	B. Reasor	n for Produ	cing this Repor	rt	
Client:	Salvation A	rmy HQ (Southl	East Regi	on)	Purpose of	this report:			
Address:	99-101 Newi London SE1 6BN	ington Causewa	ау				on requested by at work regulation		nt in accordance).
						which Inspection was carried out		7	
C Details	of the Install	lation which is	the Sub	ject of this Repor					
Installation:		Nursery - PO1			Descriptio	on of	Domestic	Commer	cial Industrial
Occupier:		-			premises	:	N/A	-	N/A
		Nursery - South	sea corp	5	Other: N/A				
Address:	Day Care Ce 28 Brookfield				Estimated	d age of wiring s	system:		15+ yrs
	Fratton			_	Evidence	of alterations		If yes	
	Portsmouth		P	D1 5HZ	or additio	ns:		estimate	d Age 4+ yrs
Record of Installation ava	ailable: N/A	Records held By:	N/A				Date of prev inspection:	lous	Not Known
D. Extent a	and Limitatic	ons Inspection	and Tes	sting					
		covered by this repo			Agreed limitatio	ons including the	e reasons (See regula	ation 634.	2)
		al Installation			Ű,	ed Limitatior			
See Add	itional Page	•			See Addi	itional Page-			
Operational Li	mitations includin	g the reasons (See	page No 8	Agreed with name	Sandra Ne	ewsham			
	rational Limita			· ·					
See Add	litional Page	-							
to July 201 It should be no	5 oted that cables c	concealed within tru	nking and co	nying schedules have be onduits, under floors, in ro nd inspector prior to the i	of spaces, and g			-	
		ndition of the				ations (In terms	of electrical safety)		
-		Condition of the							
	itional Page								
Overall asses	ssment of the inst	tallation Unsat	tisfactory	*An unsatisfactory as C2) conditions have		ates that danger	ous (code C1) and/o	r potentia	lly dangerous (code
	nendations								
'Danger preser Investigation w	nt' (code C1) or 'F <i>v</i> ithout delay is re assified as 'Impro	Potentially dangerou commended for obsovement recommen	is (code C2) servations id ded' (code C	are acted upon as a mai entified as <i>'further invest</i> C3) should be given due c	ter of urgency igation required' consideration.			·	observations classified as
				n being taken I recomr					
G. Declara	which	are described abov ation in this report, i ation taking into acc	e, having ex including the	for the inspection and tes ercised reasonable skill a observations and attach ted extent and limitations	and care when care when care when care when care when a care when	arrying out the i rovides an accu	nspection and testing	, hereby	declare that the
and address	Compliance H Golborne Ente					NICEIC	Enrolment Number	0313	62
	Kid Glove Roa Warrington, W	ad,							
Inspected and	-		Position	Electrical Test	ninoor Sime	turo	12 19 3	Data	25/00/2017
	Blake rised for issue b		Position	Electrical Test Eng	gineer Signat	lure	A B	Date	25/09/2017
	ven Skillern		Position	Technical Auditor	Signat	ture	Shillenn	Date	05/10/2017
H. Schedu		. ,		his document and this rep			attached to it.		
0	Schedule	(s) of inspection and	2	Schedule(s)	of test results a	re attached			

Copyright © Amtech Group Ltd 2012, FastTest Pro [17th Edition] v2012.0.2, PHS Compliance

I. Supply Cha	racteristics a	and Earthi	ng Arrange	ments							
Earthing Arrangements	Nur	mber and Typ	e of Live Cond	uctors	Nature of S	Supply Pa	arameters		Supply p	protective dev	ice
TN-S 🗸	a.c.	✓		d.c. N/A	Nominal Voltage	U ⁽¹⁾ 40	00 V	BS(EN)			
TN-C-S N/A	1-Phase (2 wire)	1-Ph (3 w		2 Wire N/A	Nominal Voltage	U ₀ ⁽¹⁾ 23					
TN-C N/A	2-Phase (3 wire)	N/A		3 Wire N/A	Nominal frequency	f ⁽¹⁾ 50		Туре			
	3-Phase	N/A 3-Ph	A1/A		Prospective fault current	lpf ⁽²⁾ 1.	17 kA	N/A			_
TT N/A	(3 wire)	N/A 3-Ph (4 w		Other N/A	External loop impedance	Ze ⁽²⁾ 0.2	20 Ω	Nominal current ra	ting	LIM	А
IT N/A	Other N/A				Number of supplies	1		Short circ capacity	uit	N/A	kA
	Confirmation	of supply pola	rity	×	(Note: (1) by e by measureme) by enquiry				
J. Particulars	of Installation	on Referre	ed to in the	Report							
Means of ea	rthing			Details o	finstallation Ea	rth Electr	rode (where	applicable)			
Distributor's facility	×	Type (e.g. roo tape etc.)	d(s), N/A		Locat	ion	N/A				
Installation	N/A	Resistance to	N/A		Ω						
earth electrode		Earth			Metho		N/A				
			Tielt heree and	antar dataila ao an		urement	IN/A				
Main Protectiv	e Conducto	ors	TICK DOXES and	enter details as ap							
Earthing Conductor	Material	Copper		csa 16	mm ²	C	Connection a	and Continuity	Verified	LIM	
Main protective bonding conductors	Material	Copper		csa 10	mm ²	C	Connection a	and Continuity	Verified	LIM	
Bonding of Incom	ing Service					Ν	Maximum De	emand (Load)			
Water Gas	Lightning Oil	Steel	Other Plea	se State		1	N/A	Amps			
× ✓	N/A N/A	A N/A	N/A N/A	١		F	Protective me	easure(s) agai	nst electri	ic shock	
							ADS				
Main Switch /	Switch-Fuse	e / Circuit-	Breaker / R	CD							
Location Fr	ont Of Buildir	ng - Within	DB 1			Current	10)0 A		f RCD main s	
						rating Fuse/De			operation	esidual N/	A mA
						rating or	1 1/	AA	I∆n Rated t	ime delay	A ms
Type BS(EN) 60)947-3			No of poles 2		Voltage rating	23	30 v			Δ.
	opper		Supply Conduc	tors 25	mm ²	·			time at,		A ms
material			csa								
K. Observatio)			a a a a				6 M - 1	<i></i>	
Referring to the atta						pecified at	the Extent a	and Limitations	s of the Ins	spection and te	esting section.
No reme	dial action is requ	uired. N/A	The follow	wing observations	are made	~					Further Investigation
Item No				Observat						Code	Required
1 Plea	ase see the a	additional sl	heet(s) at the	end of the re	port.					N/A	No
			een allocated to	each of the obser	vations made ab	ove to inc	dicate to the	person(s) resp	onsible fo	or the installation	on the
degree of urgency											
C1 - Danger prese				quired							
C2 - Potentially da	ingerous - urgent	t remedial action	on required	C							

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION

Board	Details	S															
то	BE COM	PLETE	D IN EVERY CAS	SE	ONLY	TO BE C	OMPLET	TED IF T	HE DIST		N BOARD	IS NOT CO	NNECTE	D DIREC	TLY TO	THE OR	IGIN
Location Distribu			Of Building actum)		Supply distribut	tion	N/A							sociated		any)	
Board	((Coma	ictum)		board is No of pl		N/A		Nomin	al Voltag	e N/A	BS(E	N)	N/A			
					·			uice for t				RCD Pole	No of	N/A			
Distribu board	tion D	DB 1				·		evice for t	ne distric								
designa	ition				Type BS	S(EN)	N/A		_	Rating	N/A	A RCD	Rating	N/A			mA
Circui	t Detail	S				r		1		1.54	1						
Circuit									rcuit	Max per-		Overcurrent	protectiv	e device		RCD	
number and phase		Cir	rcuit designation		Type of wiring	Refe- rence method	No of points served	Live mm ²	tors csa cpc mm ²	mitted disc- onnec- tion times	в	S(EN)	Type No	Rating A	Short circuit capa- city kA	Op. current I ∆ n	Max per- mitted Zs Ω
1/L1	SPARE				-	-	-	-	-	-		-	-	-	-	-	-
2/L1	SPARE				-	-	-	-	-	-		-	-	-	-	-	-
3/L1	Sockets &	Fused	Spurs - Kitchen		Α	В	8	2x2.5	2x1.5	0.4	6	009	В	32	10	30	1.15
4/L1	Lighting -	Kitchen,	, Childrens Toilet & E	Back Lobby	Α	В	6	2x1.0	2x1.0	0.4		1009	В	6	10	30	6.14
5/L1	Lighting -	Nursery	& Office		Α	В	14	3x1.0	3x1.0	0.4	6	1009	В	10	10	30	3.68
6/L1	Sockets -	Office			Α	В	5	2.5	1.5	0.4	6	1009	В	20	10	30	1.84
7/L1	Sockets -	Nursery			Α	В	4	6.0	2.5	0.4	6	1009	В	32	10	30	1.15
8/L1	Sub Mains	s(DB 2)			G	С	1	4.0	4.0	5		8 MCB	В	32	10	N/A	1.15
																<u> </u>	
Wiring	g Code																
	А		В	С		D		E			F	G		Н		0	
	PVC/P cable		PVC cables in metallic conduit	PVC cat in non-met condu	tallic	PVC cab in metall trunkir	ic	PVC ca in non-me trunk	etallic	1	'SWA bles	XLPE/SWA cables	Mine	ral insulat cables	ed	Other	

SCHEDULE OF CIRCUIT TESTS FOR THE INSTALLATION

Board	Tests							1							
ONLY T		IPLETED IF ECTLY TO T					IECTED		TE	ST INSTRU	JMENTS (SER	RIAL NUM	BERS) US	ED	
Zs	N/A	Ω	Operating times of		At I $_{\Delta}$ n	N/A	ms	Earth fai	10	1101853		RCD	101101	853	
lpf	N/A	kA	associated RCD (if any		At 5I Δ_n	N/A	ms	impedar Insulatio	n 10	1101853	;	Other	N/A		
Correct polarity	supply	 Image: A second s	Phase seq (where app	uence confir	med	N/	/A	resistano Continui	Le	1101853			N/A		
confirme		ite en el/e			anabla 4				5 10	1101055					
Details N/A	OF CIFCU	lits and/o	r equipn	nent vuin	erable t	o dama	age								
IN/A															
Circuit	Tests														
		Circ	cuit Impeda Ω				Insulation	resistance	е	p o	Maximum	R	CD operati times	ng	ы
Circuit number		g final circuit		(At lea	rcuits ist one					l a	measured earth fault	At	At	ton on	Remarks see continuation sheet
and phase	(me	easure end to	end)		umn mpleted)	Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral		loop impedance	ΙΔ _n	5l Δ n	Test button operation	Ren se cor sh
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R _{1 +} R ₂₎	(R ₂)	ΜΩ	ΜΩ	ΜΩ	MΩ	t y	Ω	ms	ms	° ⊥€	, s
1/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3/L1	0.49	0.48	0.79	0.17	N/A	N/A	LIM	>999	>999	1	0.36	29.1	29.1	1	NO
4/L1	N/A	N/A	N/A	0.57	N/A	N/A	LIM	>999	>999	1	0.78	26.7	26.0	1	NO
5/L1	N/A	N/A	N/A	0.52	N/A	N/A	LIM	>999	>999	1	0.72	19.4	19.2	1	NO
6/L1	N/A	N/A	N/A	0.20	N/A	N/A	LIM	>999	>999	1	0.40	24.6	24.9	1	NO
7/L1	N/A	N/A	N/A	0.17	N/A	N/A	LIM	>999	>999	1	0.37	24.2	27.4	1	NO
8/L1	N/A	N/A	N/A	0.23	N/A	N/A	LIM	>999	>999	1	0.44				NO
Tested	Ву	_													
Signa	ature			ø B	2			Positio	n	Electric	al Test Eng	ineer			
Nam	e	lan B	lake					Date of testing	f	25/09/2	017				

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION

Board	Details	\$		<u> </u>													
тс) BE COMP	PLETE	D IN EVERY CAS	SE	ONLY	TO BE C	OMPLET	TED IF T	HE DIST		N BOARD	IS NOT CON	NECTE	D DIREC	TLY TO	THE OR	IGIN
Locatio Distribu		Rear B Chint)	Baby Room		Supply distribut	ion	SubM	ains(D	B 1, 8/L	_1)				sociated			
Board	, i i i i i i i i i i i i i i i i i i i	,			No of pl		1]	Nomin	al Voltag	e 230	V BOD			08 RCI	J	
Distribu	ution)B 2			Overcur	rent prot	ective de	evice for t	he distrib	oution cire	cuit	Poles	No of	2			
board designa		, U Z			Type BS	S(EN)	60898	B MCB	В	Rating	32	A RCD	Rating	30			mA
Circui	t Details	S			1	1	1	1		Max	1						1
Circuit number and phase		Cir	cuit designation		Type of wiring	Refe- rence method	No of points served	conduc	rcuit tors csa	Max per- mitted disc- onnec-		Overcurrent 6	protectiv Type	e device Rating	Short circuit capa-	RCD Op. current	Max per- mitted
phase								Live mm ²	cpc mm ²	tion times			No	А	city kA		Zs Ω
1/L1	Sockets - I				A	В	3		2x1.5	0.4		8 MCB	В	20	6	N/A	1.84
2/L1			tral Heating Controls	;	A	В	1	2.5	1.5	0.4		8 MCB	В	16	6	N/A	2.30
3/L1	Lighting - I	3aby Ro	.om		A	В	6	1.5	1.0	0.4	6089	98 MCB	В	6	6	N/A	6.14
																<u> </u>	
																<u> </u>	
																<u> </u>	
Wiring	g Code																
[А		В	С		D		E		F	F	G		Н		0	
	PVC/P\ cable		PVC cables in metallic conduit	PVC cab in non-met condu	allic	PVC cab in metall trunkir	ic	PVC ca in non-me trunk	etallic	PVC/ cab	'SWA bles	XLPE/SWA cables		ral insulat cables	ed	Other	

SCHEDULE OF CIRCUIT TESTS FOR THE INSTALLATION

Board	Tests														
ONLY T		IPLETED IF ECTLY TO 1					ECTED		TE	ST INSTRI	JMENTS (SER	RIAL NUM	1BERS) US	SED	
Zs	0.44	Ω	Operating times of		At I $_{\Delta}$ n	18.3	ms	Earth fai loop impedar	10	1101853		RCD	101101	853	
lpf	0.52	kA	associated RCD (if any	y)	At 5I Δ_n	16.1	ms	Insulatio	n 10	1101853	,	Other	N/A		
Correct polarity		 Image: A set of the set of the	Phase seq (where app	uence confir propriate)	med	N/	Ά	Continui		1101853		Other	N/A		
		iits and/o			orable t	o domo	ao								
N/A		iits anu/o	requipri			o uama	ige								
1.07.1															
Circuit	Tests														
		Cire	cuit Impeda Ω				Insulation	n resistanc	e	p o	Maximum	R	CD operati	ng	<u>io</u>
Circuit number		g final circuit		(At lea	rcuits ast one					l a	measured earth fault	At	At	on	Remarks see continuation
and phase		easure end to			umn mpleted)	Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral	r i t	loop impedance	ΙΔ _n	5l Δ n	Test button operation	Rer ee cor
	-	r _n (Neutral)		(R _{1 +} R ₂₎	(R ₂)	ΜΩ	ΜΩ	ΜΩ	MΩ	y	Ω	ms	ms	Ĕ	
1/L1	N/A	N/A	N/A	0.16	N/A	N/A	LIM	>999	>999	~	0.60				NO
2/L1 3/L1	N/A N/A	N/A N/A	N/A N/A	0.08	N/A N/A	N/A N/A	LIM	>999 >999	>999 >999	1	0.52 0.84		+	+	NO NO
5/11				0.55				-999	2999	~	0.04				
														+	
														-	
														+	+
													-		
														<u> </u>	
													<u> </u>	<u> </u>	
													<u> </u>		
													+	+	
													+		
Tested	By														
Sign				1 G	2			Positio	n	Electric	al Test Eng	ineer			
Nam	e	lan B	lake					Date of	F	25/09/2					
. taili		Idli B	Iare					testing		20/09/2					

Extent of Electrical Installation covered by this report, Continued. from page 1

Testing of all sub mains, lighting and power circuits, within the constraints of the agreed limitations.

Agreed limitations including the reasons, Continued. from page 1

Unable to isolate the supply.Unable to access the sealed supply device characteristics. Ze and lpf have been taken as close to the origin as possible.

Insulation resistance testing has been carried out to regulation 612.3.3 on circuits were it was impracticable to disconnect load.

Operational Limitations including the reasons, Continued. from page 1

When counting the number of points on each circuit, the number given relates to those points positively identified and it is possible that there are others that were not found.

General condition of the installations (In terms of electrical safety), Continued. from page 1

The origin of the installation is at the front of the building, in a cupboard.

The main distribution supply enters DB 1 via mains fuses and metering equipment which in turn supplies one other distribution board within the premises.

There are two distribution boards within this installation :

DB 1 - Located at the front of the building, in the entrance lobby.

DB 2 - Located in the rear baby area.

PRESENCE & ADEQUACY OF EARTHING & BONDING

There are two other incoming services to the installation, water and natural gas.

The water stop tap could not be located at time of test. Further investigation required to verify if there is a Main Protective Bonding conductor in place.

The gas service is located in the kitchen and there is a 10mm Main Protective Bonding conductor which is suitably terminated to the pipework and in a satisfactory condition.

SUITABILITY OF SWITCHGEAR & CONTROL GEAR

Switchgear and control gear were assessed to be generally satisfactory for the uses employed.

TYPES OF WIRING SYSTEM & CONDITION

Several wiring systems have been adopted in this installation, with the majority being PVC/PVC "Twin & Earth" cable in PVC trunking, clipped direct and installed within the fabric of the building.

OTHERS:-

Apart from the defects as referenced in section K of this report, the installation seems to be in a reasonable condition in regards to its type, use and age.

ABBREVIATIONS USED IN THIS REPORT

- DB Distribution board
- MCB Miniature circuit breaker
- RCD Residual current device
- CPC Circuit protective conductor

CONDITION REPORT GUIDANCE NOTES FOR RECIPIENTS

This report is an important and valuable document which should be retained for future reference.

- 1. The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
- 2. The person ordering the Report should have received the original Report and the inspector should have retained a duplicate.
- 3. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
- 4. Where the installation incorporates residual current devices (RCD) there should be a notice at or near the device stating that it should be tested quarterly. For safety reasons it is important that this instruction is followed.
- 5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
- Some operational limitations such as such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
- 7. For items classified in Section K as C1 ("Danger Present"), the safety of those using the installation is at risk, and it is recommended that a competent person undertakes the necessary remedial work immediately.
- 8. For items classified in Section K as C2 ("Potentially Dangerous"), the safety of those using the installation may be at risk and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
- 9. Where it has been stated in Section K that an observation requires further investigation the inspection has revealed an apparent deficiency which could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
- 10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a competent person. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.



110064710 - Master

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

		CHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS	
ltem	Description		
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT		Outcome
1.1	Service cable condition		✓
1.2	Condition of Service head		✓
1.3	Condition of tails - Distributor		√
1.4	Condition of tails - Consumer		√
1.5	Condition of metering equipment		1
1.6	Condition of Isolator (where present)		√
2.0	Presence of adequate arrangements for other ser	vices, such as Microgenerators (551.6; 551.7)	N/A
3.0	AUTOMATIC DISCONNECTION OF SUPPLY		Outcome
3.1	Earthing / Bonding Arrangements (411.3; Chap 5	i4)	
3.1.1	Presence of distributor's earthing arrangement (5		√
3.1.2	Presence and condition of earth electrode connect		N/A
3.1.3	Provision of earthing / bonding labels at all approp		√
3.1.4	Confirmation of earthing conductor size (542.3; 54	43.1.1)	√
3.1.5	Accessibility and condition of earthing conductor a		√
3.1.6	Confirmation of main protective bonding conducto		FI EI
3.1.7	Condition and accessibility of main protective bon		FI El
3.1.8	Accessibility and condition of all protective bondin	g connections (543.3.2)	FI
3.2 3.2.1	FELV Source supplying at least simple separation (411.	7)	N/A
		eable with those of other systems within the premises	N/A
3.2.2	(411.7.5)		N/A
3.3	Reduced low voltage		
3.3.1	Adequacy of source (411.8.4)		N/A
3.3.2	Plugs, sockets-outlets and the like not interchang (411.8.5)	eable with those of other systems within the premises	N/A
	OTHER METHODS OF PROTECTION		
4.0	(Where any of the methods listed below are emp	loyed details should be provided)	
	Other Methods	Details	Outcome
4.1	Non-conducting location (418.1)	Details	N/A
4.2	Earth-free local equipotential bonding (418.2)		N/A
			174
4.3	Electrical separation for the supply to more than		N/A
4.5	one item of current using equipment (Sec 413; 418.3)		N/A
4.4	Double insulation (Section 412)		N/A
4.5	Reinforced insulation (Sec 412)		N/A
4.6 4.7	Use of obstacles (417.2)		N/A N/A
-	Placing out of reach (417.3)		N/A
5.0	CONSUMER UNITS / DISTRIBUTION BOARDS		Outcome
5.1	Adequacy of working space / accessibility to cons	umer unit / distribution board (132.12)	√
5.2	Security of fixing (416.2.3)		√
5.3	Condition of enclosure(s) in terms of IP rating etc	· /	1
5.4	Condition of enclosure(s) in terms of fire rating etc		1
5.5	Enclosure not damaged/deteriorated so as to imp		√
5.6	Presence of linked main switch (as required by 5	,	✓
5.7	Operation of main switch (functional check) (612.	,	✓
5.8	Manual operation of circuit-breakers and RCDs to		√
5.9	Correct identification of circuit details and protecti		C3 (see section K)
5.10	Presence of RCD quarterly test notice at or near of		√
5.11	Presence of non-standard (mixed) cable colour wa (514.14)	arning notice at or near consumer unit / distribution board	\checkmark
5.12	Presence of alternative supply warning notice near	r consumer unit / dist board (514.15)	N/A
5.13	Presence of other required labelling (Section 514		√
5.14	Examination of protective device(s) and base(s);	correct type and rating (no signs of unacceptable thermal	1
	damage, arcing and overheating (421.1.3) Single-pole protective devices in line conductor of	Ny (132 14 1 · 520 2 2)	
5.15		ly (132.14.1; 530.3.2) oles enter consumer unit / distribution board (522.8.1;	√
E 40		nes enter consumer unit / uistribution board (322.0.1;	\checkmark
5.16	522.8.11)		



	110064 INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS	710 - Master
5.0	CONSUMER UNITS / DISTRIBUTION BOARDS Continued.	Outcome
	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures	
5.17	(521.5.1)	√
5.18	RCD(s) provided for fault protection – includes RCBOs (411.4.9; 411.5.2; 531.2)	N/A
5.19 5.20	RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1) Condition of insulation of live parts (416.1)	✓ ✓
5.21	Adequacy / security of barriers (416.2)	 ✓
5.22	Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check)	1
	(612.13.1)	
5.23 5.24	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1) Correct identification of circuit protective devices (533.1)	C3 (see section K)
		•
6.0	MAIN DISTRIBUTION & FINAL CIRCUITS	Outcome
6.1	Identification of conductors (514.3.1)	<u>√</u>
6.2 6.3	Cables correctly supported throughout their run (522.8.5) (521.11.201) Condition of insulation of live parts (416.1)	√
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	 N/A
6.5	Suitability of containment systems for continued use (including flex conduit) (Section 522)	NA √
6.6	Cables correctly terminated in enclosures (Section 526)	· ·
6.7	Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (421.1; 522.6.1)	√
0.1		•
6.8	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	\checkmark
6.9	Adequacy of protective devices: type and rated current for fault protection (Section 434)	√
6.10	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	\checkmark
6.11	Coordination between conductors and overload protective devices (433.1; 533.2.1)	√
6.12	Cable installation methods / practices with regard to the type and nature of installation and external influences (Section 522)	√
6.13	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	√
6.14	Cables concealed under floors, above ceilings, in walls / partitions less than 50 mm from a surface, and in partitions containing i	metal parts.
6.14.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.101) or	N/V
	Incorporating earthed armour or sheath, or run within earthed wiring system. or otherwise protected against	
6.14.2	mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.201; 522.6.203)	Lim
6.14.3	Provision of additional protection by 30mAmp RCD (522.6.101; 522.6.103)	\checkmark
	Provision of additional protection by 30mAmp RCD	
6.15.1 6.15.2	Where reasonably likely to be used to supply mobile equipment outdoors. (411.3.3 (ii)) For all socket outlets of 20 Amp or less provided for use by ordinary people. (411.3.3 (i))	<u> </u>
6.16	Termination of cables at enclosures	√
6.16.1	Connections under undue strain (522.8)	\checkmark
6.16.2	The basic insulation of a conductor visible outside an enclosure. (526.2)	√
6.16.3	Connections of live conductors adequately enclosed. (416.1)	√
6.16.4	Adequacy of connection at point of entry to enclosure (gland, bush or similar) (522.8)	√
6.17	Provision of fire barriers, seals and protection against thermal effects (Section 527)	Lim
6.18	Band II cables segregated Separated from Band I cables (528.1)	Lim
6.19	Cables segregated / separated from non-electrical services (528.3)	√
6.21 6.22	Temperature rating of cable insulation (522.1.1; Table 52.1) Condition of circuit accessories (Section 416)	✓ ✓
6.22	Suitability of circuit accessories for external influences (512.2)	 ✓
7.0	ISOLATION AND SWITCHING	Outcome
7.1	Isolators (537.2)	C accomo
7.1.1	Presence and condition of appropriate devices for isolation (537.2.2)	\checkmark
7.1.2	Acceptable location - if local or remote from equipment in question (537.2.1.5)	√
7.1.3	Capable of being secured in the OFF position (537.2.1.2)	√
7.1.4	Correct operation verified (612.13.2)	√
7.1.5	Clearly identified by position and / or durable marking (537.2.2.6)	√
7.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.2.1.3)	N/A



		110064710 - Master
	INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS	
7.0	ISOLATION AND SWITCHING Continued.	Outcome
7.2 7.2.1	Switching off for mechanical maintenance (537.3) Presence and condition of appropriate devices (537.3.1.1)	(
7.2.1	Acceptable location / Clearly identified by position and or durable marking (537.3.2.4)	√
7.2.3	Capable of being secured in the OFF position (537.3.2.3)	 √
7.2.4	Correct operation verified (612.13.2)	√
7.2.5	Clearly identified by position and / or durable marking (537.2.2.6)	√
7.3 7.3.1	Emergency switching / stopping (537.4) Presence and condition of appropriate devices (537.4.1.1)	N/A
7.3.1	Readily accessible for operation where danger might occur (537.4.2.5)	N/A N/A
7.3.3	Correct operation Verified (537.4.2.6)	N/A
7.3.4	Clearly identified by position and / or durable marking (537.4.2.7)	N/A
7.4	Functional switching (537.5)	,
7.4.1	Presence and condition of appropriate devices (537.5.1.1) Correct operation verified (537.5.1.3; 537.5.2.2)	√
		v
8.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)	Outcome
8.1	Condition of equipment in terms of IP rating etc (416.1)	1
8.2 8.3	Equipment dose not constitute a fire hazard (Section 421) Enclosure not damaged deteriorated so as to impair safety (Section 416)	√
8.4	Suitability for the environment and external influences (512.2)	 ✓
8.5	Security of fixing (416.2.3)	· · · · · · · · · · · · · · · · · · ·
8.6	Recessed luminaries (down lighters)	
8.6.1	Correct type of lamps fitted (559.4.1)	√
8.6.2	Installed to minimize build-up of heat by use of "fire rated" fittings. Insulation displacement box or similar. Cable entry holes in ceiling above luminaries, sized or sealed so as to restrict the spread of fire: (421.1.1)	Lim
8.6.3	No signs of overheating to surrounding building fabric (559.5.1)	
8.6.4	No signs of overheating to conductors / terminations (526.1)	√
9.0	LOCATION(S) CONTAINING A BATH OR SHOWER	Outcome
9.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA (701.411.3.3)	N/A
9.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	N/A
9.3	Shaver sockets comply with BS EN 61558-2-5 formally BS 3535 (701.512.3)	N/A
9.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)	N/A
9.5	Low Voltage (e.g.230 volts) socket outlets at least 3m fromZone 1 (701.512.3)	N/A
9.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	N/A
9.7	Suitability of equipment for installation in a particular zone (701.512.3)	N/A
9.8	Suitability of current-using equipment for particular position within the location (701.55)	N/A
10.0	ADDITIONAL INSPECTION FOR APPLICABLE SPECIAL LOCATIONS	Outcome
10.1	Swimming pools and other basins (702)	N/A
10.2	Rooms and cabins containing sauna heaters (703)	N/A
10.3	Construction and demolition site installations (704)	N/A
10.4 10.5	Agricultural and horticultural premises (705) Conducting locations with restricted movement (706)	N/A
10.5	Electrical installations in caravan . Camping parks and similar locations (708)	N/A N/A
10.7	Marinas and similar locations (709)	N/A N/A
10.8	Medical locations (710)	N/A
10.9	Exhibitions, shows and stands (711)	N/A
10.10	Solar photovoltaic (PV) power supply systems (712)	N/A
10.11	Mobile or transportable units (717)	N/A
10.12	Electrical installations in caravans and motor caravans (721) Electric Vehicle Charging Stations (722)	N/A N/A
10.13	Operating and maintenance gangways (729)	N/A N/A
	Temporary electrical installations for structures, amusement devices and booths at fairgrounds, amusement	
10.15	parks and circuses. (740)	N/A
10.16	Floor and ceiling heating systems (753)	N/A
10.17	Outdoor lighting Installations (714)	N/A
10.18	Extra -low voltage lighting installations (715)	N/A



			Sect	tion K: Observations	
			propriate, has been allocated to o y for remedial action.	each of the observations made above to indicate to the person(s) responsible for the)
				C1 - Danger present. Risk of injury. Immediate remedial action required	0
				C2 - Potentially dangerous - urgent remedial action required	0
				C3 - Improvement recommended	2
				FI - Further investigation required	1
				110064710 - Master	
				Description	Outcome
Item No	DB Reference	Make & Model (if applicable)	Circuit Designation / Location	Observation / Regulation	Code
1	N/A	N/A	Main Water Service	Unable to locate and verify the Main Protective Bonding Conductor is present at the main incoming water service. Reg 411.3.1.2	FI
2	DB 1	Contactum	Front Of Building	A detailed legible diagram, chart or table or equivalent form of information has not been provided in the vicinity of the distribution board indicating type and composition of circuits as well as other relevant information. Reg 514.9.1	C3
3	DB 2	Chint	Rear Baby Room	A detailed legible diagram, chart or table or equivalent form of information has not been provided in the vicinity of the distribution board indicating type and composition of circuits as well as other relevant information. Reg 514.9.1	C3